



12 South Center Street  
Bensenville, IL 60106

Office: 630.350.3404  
Fax: 630.350.3438  
[www.bensenville.il.us](http://www.bensenville.il.us)

**VILLAGE BOARD**

**President**  
Frank Soto

**Board of Trustees**  
Rosa Carmona  
Frank DeSimone  
Annie Jaworska  
David Majeski  
Martin O'Connell  
Henry Wasseler

**Village Clerk**  
Ilsa Rivera-Trujillo

**Village Manager**  
Evan K. Summers

September 26, 2016

Mr. Tom Culig  
ECG  
105 South York Road  
Elmhurst, Illinois 60126

Re: September 26, 2016 FOIA Request

Dear Mr. Culig:

I am pleased to help you with your September 26, 2016 Freedom of Information Act ("FOIA"). Your request was received by the Village of Bensenville on September 26, 2016. You requested copies of the items indicated below:

*"Site= 1151 S. York Road (currently a PNC Bank). Please provide any info pertaining to building construction permits, underground or aboveground storage tanks, environmental or hazardous material response actions, environmental liens."*

After a search of Village files, the following documents are enclosed to fulfill your request:

- 1) Village of Bensenville Records Responsive to Your Request. (16 pgs.)

These are all of the documents that can be discovered responsive to your request.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

  
Corey Williamsen  
Freedom of Information Officer  
Village of Bensenville



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020 or (217)785-5878

FOR OFFICE USE ONLY	
Facility #	2-021189
Permit #	3647-96UPG
Request Rec'd	12-11-96
Amended Date	
Approval Date	12-20-96DT
Permit Expires	6-20-97

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Shell Oil Co          1415 W 22nd          Oak Brook, IL 60522</p> <p>Contact:</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Shell s/s          1151 S York and Grand          Bensenville, DUPAGE CO., IL</p> <p>Contact:</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (1)8,000 gallon and (2)10,000 gallon
- (b) *Type of tanks:* Existing single wall fiberglass
- (c) *Type of piping:* Existing single wall fiberglass
- (d) *Product to be stored in each tank:* Gasoline
- (e) *Type of leak detection being used:*  
     *Tank:* Existing  
     *Piping:* Existing Red Jacket FX-2 line leak detectors
- (e) *Corrosion Protection being installed:*  
     *Tank:* Existing  
     *Piping:* Existing
- (g) *Spill containment devices:* Installing OPW 101 BG spill containment manholes
- (h) *Overfill prevention devices:* Existing

**RECEIVED**  
 DEC 27 1996

**BENSENVILLE FIRE DEPT.**  
**Bensenville, IL**

(4) Owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification Form for Underground Storage Tank Form. Please note a form has been forwarded to the name and address shown in Item 1 ( All pages of this form must be completed).

**(5) SPECIAL CONTINGENCIES:**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

City Tank and Pump Inc  
 7350 Channel Rd  
 Skokie, IL 60076

Contact Person: Gregory J Kuhl  
 Phone: 947-677-5613

Contractor Registration # IL667 exp2-24-97

Sincerely,

\_\_\_\_\_  
 W. Dale Tanke, Storage Tank Safety Engineer

cc: Storage Tank Safety Specialist - Stern  
 Fire Department  
 Office Associate - js  
 Division File  
 (Rev. - 2/95)



DIVISION of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020 or (217)785-5878

RECEIVED  
 NOV 18 1997

Facility # 2021189  
 Permit # 3398-97 REM

APPLICATION for Permit for **REMOVAL** of Underground Storage Tanks (Please type or print clearly)

(1) **OWNER OF TANKS** - Corporation, partnership, or other business entity: (Must be mailing address)

Shell Oil Co.  
 Name  
 1415 W. 22nd St.  
 Street Address  
 Oak Brook, Il. 60522  
 City State Zip  
 Stephanie Zertuche 630-572-5840  
 Contact Person Phone

(2) **FACILITY** - Facility ID # 2-021189  
 (Name and address where tanks are located:)

Shell S/S  
 Name  
 1151 S. York & Grand  
 Street Address  
 Bensenville, Il. DuPage  
 City State Zip County  
 Contact Person Phone

(3) **TANK(S)**: Fill in the appropriate blanks for the tank(s) to be removed. Attach additional sheet(s) if more space is needed.

# of Tanks	Capacity in gallons	Product to be stored	Date tank last used	# of Tanks	Capacity in gallons	Product to be stored	Date tank last used
1	550 gal.	waste oil	still in use				

(4) **CONTAMINATED SITE** (complete this section for sites where a release has been reported). Reminder: Releases or suspected releases must be reported to IEMA at (800)782-7860 within 24 hours:

IEMA Incident # \_\_\_\_\_

(5) **CONTRACTOR**: I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that all information submitted is true, accurate and complete.

City Tank & Pump, Inc.  
 Company Name  
 7350 Channel Rd.  
 Address  
 Skokie, Il. 60076  
 City State Zip  
 847-677-5613 847-677-1416  
 Telephone # Fax #  
 667 3-3-98  
 IL Contractor License # Expiration Date  
 Gregory J. Kuhl Vice President  
 Name of Authorized Representative Title or Position  
 Signature Date


**FOR OFFICE USE ONLY**

After receiving an approved permit, the Contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office at (217)785-1020 or (217)785-5878 between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

Permission to remove underground storage tank(s) is hereby granted. Such removal shall not commence until 12-18-97.

A seventy-two hour (3 working day) notice to this office is required to confirm final date of removal for our Inspector to be on site.

12-3-97 W. Dale Tanke  
 Approval Date Approved  
6-3-98  
 Permit Expires



(Complete the back side)



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020 or (217)785-5878

RECEIVED

DEC 31 1997

FOR OFFICE USE ONLY  
 Facility # 2021189  
 Permit # 0091-98 REM

APPLICATION for Permit for REMOVAL of Underground Storage Tanks. (Please type or print clearly)

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: (Must be mailing address)

Shell Oil Company  
 Name  
 1415 W. 22nd Street  
 Street Address  
 Oak Brook IL 60522  
 City State Zip  
 Stephanie Zertuche 630.572.5840  
 Contact Person Phone

(2) FACILITY - Facility ID # 2-021189

(Name and address where tanks are located:)

Shell Station  
 Name  
 1151 S. York Rd (@ Grand)  
 Street Address  
 Bensenville IL 60106 DuPage  
 City State Zip County  
 Stephanie Zertuche 630.572.5840  
 Contact Person Phone

(3) TANK(S): Fill in the appropriate blanks for the tank(s) to be removed. Attach additional sheet(s) if more space is needed.

# of Tanks	Capacity in gallons	Product to be stored	Date tank last used	# of Tanks	Capacity in gallons	Product to be stored	Date tank last used
1	550	Waste Oil	Currently in use				

RECEIVED  
 JAN 16 1998  
 BENSENVILLE FIRE DEPT.  
 Bensenville, IL

(4) CONTAMINATED SITE (complete this section for sites where a release has been reported). Reminder: Releases or suspected releases must be reported to IEMA at (800)782-7860 within 24 hours:

MA Incident # \_\_\_\_\_

(5) CONTRACTOR: I certify under penalty of law that I have personally examined and am familiar with the information submitted in this application and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that all information submitted is true, accurate and complete.

Performance Tank, Inc.  
 Company Name  
 1621 E. Carboy Rd, Suite 102  
 Address  
 Arlington Heights IL 60005  
 State Zip  
 847.290.8265 847.290.8266  
 phone # Fax #  
 881 10-17-98  
 10798  
 Contractor License # Expiration Date  
 Brian Zyrkowski Coordinator  
 Date of Authorized Representative Title or Position  
 12/23/97  
 Signature Date

FOR OFFICE USE ONLY

After receiving an approved permit, the Contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office at (217)785-1020 or (217)785-5878 between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

Permission to remove underground storage tanks is hereby granted. Such removal shall not commence until 1-30-98.  
 A seventy-two hour (3 working day) notice to this office is required to confirm final date of removal for our inspector to be on site.  
1-12-98  
 Approval Date Approved  
7-12-98  
 Permit Expires  
 W. Dale Tanke



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020 or (217)785-5878

FOR OFFICE USE ONLY	
Facility #	2-021189
Permit #	3646-97 INS
Request Rec'd	11-18-97
Amended Date	
Approval Date	01-01-98
Permit Expires	07-01-98


**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Shell Oil Company          1415 W. 22nd Street          Oak Brook, IL 60522          Contact: Stephanie Zertuche 630-572-5840</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Shell Service Station          1151 S. York &amp; Grand          Bensenville, DUPAGE CO., IL          Contact:</p>
---	--

**(3) INSTALLATION OF TANKS:**

- (a) *Number and size of tanks being installed:* (1) 550 gallon
- (b) *Type of tanks:* Double wall fiberglass
- (c) *Type of piping:* Double wall fiberglass for the drain line from the building to the tank
- (d) *Product to be stored in each tank:* Waste Oil
- (e) *Type of leak detection being used:*  
     *Tank:* Veeder Root TLS-350 automatic tank gauge  
     *Piping:* None required
- (e) *Corrosion Protection being installed:*  
     *Tank:* Fiberglass  
     *Piping:* Fiberglass
- (g) *Spill containment devices:* Fluid containment spill containment manhole (this tank is filled by separate transfers of no more than 25 gallons)
- (h) *Overfill prevention devices:* Float vent valve



**(4) Owner must notify this Office when completion of tank installation has occurred, on the Notification Form for Underground Storage Tank Form. Please note a form has been forwarded to the name and address shown in Item 1 ( All pages of this form must be completed).**

**(5) SPECIAL CONTINGENCIES:** Vent must be at least 4 ft from all building openings

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
City Tank & Pump, Inc. 7350 Channel Road Skokie, IL 60076	Contact Person: Gregory J. Kuhl Phone: 847-677-5613 Contractor Registration # IL 667 Exp 03-03-98

Sincerely, W. Dale Tanke  
 W. Dale Tanke, Storage Tank Safety Engineer

cc: Storage Tank Safety Specialist - Stern  
 Fire Department  
 Office Associate - js  
 Division File  
 (Rev. - 2/95)



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020 or (217)785-5878

FOR OFFICE USE ONLY	
Facility #	2-021189
Permit #	0659-98 UPG
Request Rec'd	01-27-98
Amended Date	
Approval Date	03-06-98 SI
Permit Expires	09-06-98

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Shell Oil Co          1415 W 22nd St          Oak Brook, IL 60522</p> <p>Contact: Stephanie Zertuche 630-572-5840</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Shell S/S          1151 S York &amp; Grand          Bensenville, DUPAGE CO., IL</p> <p>Contact:</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (1) 8,000 gallon and (2) 10,000 gallon
- (b) *Type of tanks:* Existing single wall fiberglass
- (c) *Type of piping:* Existing double wall fiberglass
- (d) *Product to be stored in each tank:* Gasoline
- (e) *Type of leak detection being used:*  
 Tank: Installing Veeder root TLS 350 automatic tank gauges  
 Piping: Existing
- (e) *Corrosion Protection being installed:*  
 Tank: Existing  
 Piping: Existing
- (g) *Spill containment devices:* Existing
- (h) *Overflow prevention devices:* Existing

*Shirley [unclear]  
 Extension  
 of permits*

**EXTENSION  
 Permit Expires  
 3-6-99 2x0**

(4) Owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification Form for Underground Storage Tank Form. Please note a form has been forwarded to the name and address shown in Item 1 ( All pages of this form must be completed).

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p>City Tank &amp; Pump Inc          7350 Channel Rd          Skokie, IL 60522</p>	<p>Contact Person: Greg Kuhl          Phone: 847-677-5613</p> <p>Contractor Registration # IL 667 Exp 03-03-99</p>
---	--

Sincerely, W. Dale Tanke  
 W. Dale Tanke, Storage Tank Safety Engineer

cc: Storage Tank Safety Specialist - Stern  
 Fire Department  
 Office Associate - js  
 Division File  
 (Rev. - 1/98)

WDT: vlc





OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020 or (217)785-5878

**FOR OFFICE USE ONLY**  
 Facility # 2-021189  
 Permit # 00408-1999INS  
 Request Rec'd 11/04/1998  
 Amended Date  
 Approval Date 01/29/1999 si  
 Permit Expires 07/29/1999

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Equilon Enterprises Llc          630 E Diehl Road Suite 103          Naperville, IL 60563</p> <p>Contact: Lewis Stephen (630) 276-4213</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Shell Service Station          1151 S York Grand          Bensenville, Du Page Co., IL</p> <p>Contact: Zurtucke Stephanie (630) 572-5840</p>
--	--

**(3) INSTALLATION OF TANKS:**

- (a) *Number and size of tanks being installed:* (TK # 5) 1,000 gal
  - (b) *Type of tanks:* TK # 5 Fluid Containment double wall fiberglass brine filled
  - (c) *Type of piping:* TK # 5 Ameron double wall fiberglass
  - (d) *Product to be stored in each tank:* TK # 5 Used Oil
  - (e) *Type of leak detection being used:*  
 Tank: TK # 5 Veeder Root TLS 350 hydrostatic reservoir sensor, TK # 5 Veeder Root TLS350 automatic tank gauge  
 Piping: TK # 5 Veeder Root TLS350 Interstitial Piping Sump Sensors, TK # 5 gravity feed
  - (f) *Corrosion Protection being used:*  
 Tank: TK # 5 Fiberglass  
 Piping: TK # 5 Fiberglass
  - (g) *Spill containment devices:* TK # 5 EBW 705 Spill Containment Manhole
  - (h) *Overfill prevention devices:* TK # 5 OPW 53VM Ball Float Vent Valve
- (4) Owner must notify this Office when completion of tank installation has occurred, on the Notification Form for Underground Storage Tank Form. Please note a form has been forwarded to the name and address shown in Item 1 (All pages of this form must be completed).
- (5) **SPECIAL CONTINGENCIES:** This permit replaces previous permit 0974-98 INS

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p>Performance Tank Inc          1621 E Carboy Rd Suite 102          Arlington Heights, IL 60005</p>	<p>Contact Person: Tim Berg          Phone: (847) 290-8266          Contractor Registration # IL-881 Exp. 10/27/1999</p>
---	--

Sincerely, W. Dale Tanke  
 W. Dale Tanke, Storage Tank Safety Engineer

cc: Storage Tank Safety Specialist - Stern  
 Fire Department  
 Office Associate - js  
 Division File  
 (Rev. - 1/98)

WDT:





OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020 or (217)785-5878

RECEIVED  
 DEC 31 1997

FOR OFFICE USE ONLY  
 Facility # 2021189  
 Permit # 0091-98 REM

DIV. OF PETROLEUM & CHEMICAL SAFETY  
 APPLICATION for Permit for **REMOVAL** of Underground Storage Tanks. (Please type or print clearly)

(1) **OWNER OF TANKS** - Corporation, partnership, or other business entity: (Must be mailing address)

Shell Oil Company

Name  
 1415 W. 22nd Street  
 Street Address  
 Oak Brook IL 60522  
 City State Zip  
 Stephanie Zertuche 630.572.5840  
 Contact Person Phone

(2) **FACILITY** - Facility ID # 2-021189  
 (Name and address where tanks are located:)

Shell Station

Name  
 1151 S. York Rd (@ Grand)  
 Street Address  
 Bensenville IL 60106 DuPage  
 City State Zip County  
 Stephanie Zertuche 630.572.5840  
 Contact Person Phone

(3) **TANK(S)**: Fill in the appropriate blanks for the tank(s) to be removed. Attach additional sheet(s) if more space is needed.

# of Tanks	Capacity in gallons	Product to be stored	Date tank last used	# of Tanks	Capacity in gallons	Product to be stored	Date tank last used
1	550	Waste Oil	Currently in use				

(4) **CONTAMINATED SITE** (complete this section for sites where a release has been reported). Reminder: Releases of suspected releases must be reported to IEMA at (800)782-7860 within 24 hours:

IEMA Incident # \_\_\_\_\_

(5) **CONTRACTOR**: I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that all information submitted is true, accurate and complete.

Performance Tank, Inc.

Company Name  
 1621 E. Carboy Rd, Suite 102  
 Address  
 Arlington Heights IL 60005  
 City State Zip  
 847.290.8265 847.290.8266  
 Telephone # Fax #  
 881 10-27-98  
 10/98  
 Contractor License # Expiration Date  
 Brian Zyrkowski Coordinator  
 Name of Authorized Representative Title or Position  
 Signature Date  
 12/23/97

RECEIVED  
 JAN 1 1998

FOR OFFICE USE ONLY

BENSENVILLE FIRE DEPT.

After receiving an approved permit, the Contractor before the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office at (217)785-1020 or (217)785-5878 between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

Permission to remove underground storage tank(s) is hereby granted. Such removal shall not commence until 1-30-98

A seventy-two hour (3 working day) notice to this office is required to confirm final date of removal for our inspector to be on site.

Approval Date  
1-12-98  
7-12-98  
 Permit Expires

Approved  
*W. Dale Tanke*

**EXTENSION**  
 Permit Expires  
1-12-99



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020 or (217)785-5878

**FOR OFFICE USE ONLY**  
 Facility # 2-021189  
 Permit # 00170-2000UPG  
 Request Rec'd 01/19/2000  
 Amended Date  
 Approval Date 01/25/2000 MWB  
 Permit Expires 07/25/2000

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Equilon Enterprises LLC          603 N. Diehl Road, Suite 103          Naperville, IL 60563</p> <p>Contact:</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Shell Service Station          1151 S York Rd @ Grand          Bensenville, Du Page Co., IL</p> <p>Contact: Zurtucke Stephanie (630) 572-5840</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 10,000 gallons, (TK # 3) - 8,000 gallons
- (b) *Type of tanks:* (TK # 1, 2, 3) - Existing single wall fiberglass
- (c) *Type of piping:* (TK # 1, 2, 3) - (Installing) Ameron double wall fiberglass
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (e) *Type of leak detection being used:*  
  - Tank:* (TK # 1, 2, 3) - Existing automatic tank gauging
  - Piping:* (TK # 1, 2, 3) - Existing interstitial monitoring to remain, (TK # 1, 2, 3) - (Installing) Vaporless LD2000 Mechanical Line Leak Detector
- (f) *Corrosion Protection being used:*  
  - Tank:* (TK # 1, 2, 3) - Existing fiberglass
  - Piping:* (TK # 1, 2, 3) - (Installing) Fiberglass
- (g) *Spill containment devices:* (TK # 1, 2, 3) - Existing spill containment manhole
- (h) *Overfill prevention devices:* (TK # 1, 2, 3) - Existing drop tube valve

**(4) Owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification Form for Underground Storage Tank Form. Please note a form has been forwarded to the name and address shown in Item 1 ( All pages of this form must be completed).**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p>Performance Tank Inc          1621 E Carboy Rd Suite 102          Arlington Heights, IL 60005</p>	<p>Contact Person: Tim Berg          Phone: (847) 290-8265          Contractor Registration # IL-881 Exp. 10/27/2000</p>
---	--

Sincerely, W. Dale Tanke  
 W. Dale Tanke, Storage Tank Safety Engineer

cc: Storage Tank Safety Specialist - Johnson  
 Fire Department  
 Office Coordinator - js  
 Division File  
 (Rev. - 1/98)

WDT:



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020 or (217)785-5878

**FOR OFFICE USE ONLY**  
 Facility # 2-021189  
 Permit # 02224-2000UPG  
 Request Rec'd 11/16/2000  
 Amended Date  
 Approval Date 11/27/2000 DT  
 Permit Expires 05/27/2001



**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of the Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for upgrade or repair of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Equilon Enterprises LLC 103 N. Diehl Road, Suite 103 Naperville, IL 60563  Contact: A. Martinez (630) 276-4212	<b>(2) FACILITY</b> - name and address where tanks are located:  Shell Service Station 1151 S York Rd @ Grand Bensenville, Du Page Co., IL  Contact: Zurtucke Stephanie (630) 572-5840
--	--

**3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 10,000 gallons, (TK # 3) - 8,000 gallons
- (b) *Type of tanks:* (TK # 1, 2, 3) - Existing double wall fiberglass
- (c) *Type of piping:* (TK # 1, 2, 3) - (Installing) Ameron double wall fiberglass
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (e) *Type of leak detection being used:*  
  - Tank:* (TK # 1, 2, 3) - Existing automatic tank gauging
  - Piping:* (TK # 1, 2, 3) - (Installing) Veeder Root Pressurized electronic line leak detector
- (f) *Corrosion Protection being used:*  
  - Tank:* (TK # 1, 2, 3) - Existing fiberglass
  - Piping:* (TK # 1, 2, 3) - (Installing) Fiberglass
- (g) *Spill containment devices:* (TK # 1, 2, 3) - Existing spill containment manhole
- (h) *Overfill prevention devices:* (TK # 1, 2, 3) - Existing automatic shut off

Owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification Form for Underground Storage Tank Form. Please note a form has been forwarded to the name and address shown in Item 1 ( All pages of this form must be completed).

**SPECIAL CONTINGENCIES:**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Premier Petroleum Equip Ser Corp 50 Delta Lane Oak Grove Village, IL 60007	Contact Person: William Renner Phone: (847) 766-5006  Contractor Registration # IL-390 Exp. 02/27/2001
---	---

Sincerely,   
 W. Dale Tanke, Storage Tank Safety Engineer

Storage Tank Safety Specialist - Johnson  
 Fire Department  
 Office Coordinator - JS  
 Division File  
 (Rev. - 1/98)

DT:



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020 or (217)785-5878  
**Amended/Revised**

**FOR OFFICE USE ONLY**  
 Facility # 2-021189  
 Permit # 02224-2000UPG  
 Request Rec'd 11/16/2000  
 Amended Date 02/09/2001/Rev 4-3  
 Approval Date 11/27/2000 DT  
 Permit Expires 05/27/2001

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for upgrade or repair of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Equilon Enterprises LLC          603 Diehl Road, Suite 103          Naperville, IL 60563          Contact:</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Shell Service Station          1151 S York Rd @ Grand          Bensenville, Du Page Co., IL          Contact: Zurtucke Stephanie (630) 572-5840</p>
--	---


**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 10,000 gallons, (TK # 3) - 8,000 gallons
- (b) *Type of tanks:* (TK # 1, 2, 3) - Existing Single wall fiberglass
- (c) *Type of piping:* (TK # 1, 2, 3) - (Installing) Ameron double wall fiberglass
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (e) *Type of leak detection being used:*  
  - Tank:* (TK # 1, 2, 3) - Existing automatic tank gauging
  - Piping:* (TK # 1, 2, 3) - (Installing) Veeder Root Pressurized electronic line leak detector, (TK # 1, 2, 3) - (Installing) Veeder Root TLS350 interstitial piping sump sensors to accommodate submersible sump, (TK # 1, 2, 3) - (Installing) Beaudreau 510 interstitial piping sump sensor to accommodate dispenser sump, (TK # 1, 2, 3) - (Installing) Beaudreau 516 interstitial piping sump sensor to accommodate dispenser sump
- (f) *Corrosion Protection being used:*  
  - Tank:* (TK # 1, 2, 3) - Existing fiberglass
  - Piping:* (TK # 1, 2, 3) - (Installing) Fiberglass
- (g) *Spill containment devices:* (TK # 1, 2, 3) - Existing spill containment manhole
- (h) *Overfill prevention devices:* (TK # 1, 2, 3) - Existing automatic shut off

(4) Owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification Form for Underground Storage Tank Form. Please note a form has been forwarded to the name and address shown in Item 1 ( All pages of this form must be completed).

(5) **SPECIAL CONTINGENCIES:** All steel flex connectors or risers in contact with native soils must have corrosion protection.

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Premier Petroleum Equip Ser Corp          2550 Delta Lane          Elk Grove Village, IL 60007</p>	<p>Contact Person: William Renner          Phone: (847) 766-5006          Contractor Registration # IL-390 Exp. 02/27/2002</p>

Sincerely,   
 W. Dale Tanke, Storage Tank Safety Engineer

cc: Storage Tank Safety Specialist - Johnson  
 Fire Department  
 Office Coordinator -JS  
 Division File  
 (Rev. - 1/98)

WDT:



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Technical Services  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

**FOR OFFICE USE ONLY**  
 Facility # 2-021189  
 Permit # 00251-2007UPG  
 Request Rec'd 02/27/2007  
 Amended Date  
 Approval Date 02/27/2007 DS  
 Permit Expires 08/27/2007

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Shell Oil Products U.S.          603 E. Diehl Road, Suite 103, Attn: HSE Coordinator          Naperville, IL 60563-4910          Contact: Michelle Knapp (847) 915-0250</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Shell Service Station          1151 S. York Rd @ Grand          Bensenville, Du Page Co., IL          Contact:</p>
---	--


**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000 gallons
- (b) Type of tanks:
- (c) Type of piping:
- (d) Product to be stored in each tank: (TK # 1) - Gasoline
- (e) Type of leak detection being used:  
     Tank:  
     Piping:
- (f) Corrosion Protection being used:  
     Tank:  
     Piping:
- (g) Spill containment devices:
- (h) Overfill prevention devices:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** This work has been previously completed under emergency repair procedures. Permit issued to repair regular primary piping leak at dispenser sump #1/2, existing piping is DWFRP (3" over 2" Ameron)

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Performance Tank Inc          730 Creel Drive          Wood Dale, IL 60191</p>	<p>Contact Person: Tim Berg          Phone: (630) 860-9500          Contractor Registration # IL-881 Exp. 10/27/2008</p>

Sincerely,   
 Daniel G. Starks, Engineer Technician II

cc: Storage Tank Safety Specialist - Billman  
 Fire Department  
 Office Coordinator - KB  
 Division File  
 (Rev. - 1/98)

WDT:



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Technical Services  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

**FOR OFFICE USE ONLY**  
 Facility # 2-021189  
 Permit # 01681-2007REM  
 Request Rec'd 10/11/2007  
 Amended Date  
 Approval Date 10/15/2007 DS  
 Permit Expires 4/15/2008

**REVISED**

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Shell Oil Products US          7300 West Friendly Avenue, P.O. Box 22087, Attn: CMS          Mailstop F-76          Greensboro, NC 27420-2087          Contact: Michael Lewis (800) 253-8054</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Shell Service Station #136860          1151 South York Rd @ Grand          Bensenville, Du Page Co., IL.          Contact: Jeff Root (630) 641-9394</p>
--	---

**(3) REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed:* (TK # 1, 2) - 10,000 gallons, (TK # 3) - 8,000 gallons, (TK # 5) - 1,000 gallons
- (b) *Product stored in each tank:* (TK # 1, 2, 3) - Gasoline, (TK # 5) - Used Oil
- (c) *Reason of tanks being removed:*
- (d) *If tank(s) is leaking, indicate IEMA incident number:*
- (e) *Date each tank was last used:* (TK # 1, 2, 3, 5) - 08/09/2007

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form This form can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 170.640 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES:** Revision to add tank #5 (The application for this permit cannot be located for review at this time. Contractor called 11/19/07 and stated that tank #5 was included for removal on the permit application).

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>B &amp; B Construction &amp; Exc Co Inc          19500 South 97th Avenue          Mokena, IL 60448</p>	<p>Contact Person: Bill Carlson          Phone: (708) 479-3434          Contractor Registration # IL-1602 Exp. 10/06/2008</p>

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 6/07)



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Technical Services  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

**FOR OFFICE USE ONLY**  
 Facility # 2-021189  
 Permit # 01681-2007REM  
 Request Rec'd 10/11/2007  
 Amended Date  
 Approval Date 10/15/2007 DS  
 Permit Expires 4/15/2008

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Shell Oil Products US          7300 West Friendly Avenue, P.O. Box 22087, Attn: CMS          Mailstop F-76          Greensboro, NC 27420-2087          Contact: Michael Lewis (800) 253-8054</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Shell Service Station #136860          1151 South York Rd @ Grand          Bensenville, Du Page Co., IL          Contact: Jeff Root (630) 641-9394</p>
--	--

**(3) REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed:* (TK # 1, 2) - 10,000 gallons, (TK # 3) - 8,000 gallons
- (b) *Product stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (c) *Reason of tanks being removed:* No longer use
- (d) *If tank(s) is leaking, indicate IEMA incident number:*
- (e) *Date each tank was last used:* (TK # 1, 2, 3) - 08/09/2007

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form This form can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 170.640 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          B &amp; B Construction &amp; Exc Co Inc          19500 South 97th Avenue          Mokena, IL 60448</p>	<p>Contact Person: Dave Carlson          Phone: (708) 479-3434          Contractor Registration # IL-1602 Exp. 10/06/2008</p>
--	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 6/07)



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Technical Services  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

**FOR OFFICE USE ONLY**  
 Facility # 2-021189  
 Permit # 00942-2011REM  
 Request Rec'd 09/26/2011  
 Amended Date  
 Approval Date 9/26/2011 DS  
 Permit Expires 3/26/2012

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Shell Oil Products US c/o Gilbarco Veeder-Root          7300 West Friendly Avenue, P.O. Box 22087, Attn: CMS          Mailstop F-76          Greensboro, NC 27420-2087          Contact: Keith McIntyre (419) 868-6800</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Shell Service Station #136860          1151 South York Rd @ Grand          Bensenville, Du Page Co., IL          Contact: Jeff Root (630) 641-9394</p>
--	--

**(3) REMOVAL OF TANKS:**

- (a) Number and size of tanks being removed: (TK # 6) - 1,500 gallons
- (b) Description/location of piping being removed:
- (c) Product stored in each tank: (TK # 6) - Heating Oil
- (d) Reason of tanks being removed:
- (e) If tank(s) is leaking, indicate IEMA incident number:
- (f) Date each tank was last used: (TK # 6) - 12/31/1973

*ACTUAL 6,000 GALLONS*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          Performance Tank, Inc.          730 Creel Drive          Wood Dale, IL 60191</p>	<p>Contact Person: Jack Meck          Phone: (630) 860-9500          Contractor Registration # IL-881 Exp. 10/27/2012</p>
--	---

Sincerely,

*Daniel H. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 9/10)



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Technical Services  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

**FOR OFFICE USE ONLY**  
 Facility # 2-021189  
 Permit # 01105-2011REM  
 Request Rec'd 11/10/2011  
 Amended Date  
 Approval Date 11/10/2011 JC  
 Permit Expires 5/10/2012

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Shell Oil Products US c/o Gilbarco Veeder-Root          7300 West Friendly Avenue, P.O. Box 22087, Attn: CMS          Mailstop F-76          Greensboro, NC 27420-2087          Contact: Keith McIntyre (419) 868-6800</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Shell Service Station #136860          1151 South York Rd @ Grand          Bensenville, Du Page Co., IL          Contact: Jeff Root (630) 641-9394</p>
--	--

**(3) REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed:* (TK # 7) - 1,500 gallons
  - (b) *Description/location of piping being removed:*
  - (c) *Product stored in each tank:* (TK # 7) - Heating Oil
  - (d) *Reason of tanks being removed:*
  - (e) *If tank(s) is leaking, indicate IEMA incident number:*
  - (f) *Date each tank was last used:* (TK # 7) - 12/31/1973
- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) **SPECIAL CONTINGENCIES:** Removing tank and associated piping.

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Performance Tank, Inc.          730 Creel Drive          Wood Dale, IL 60191</p>	<p>Contact Person: Jack Meck          Phone: (630) 860-9500          Contractor Registration # IL-881 Exp. 10/27/2012</p>

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 9/10)