



NOTES:

1. TO BE FORMED WITH 2" x 6" BOARDS OR STEEL FORMS.
2. TOOLED JOINTS SHALL BE 1/2".
3. EXPANSION JOINTS SHALL BE 3/4" BITUMINOUS IMPREGNATED FIBERBOARD, AT DRIVEWAYS AND OTHER CONCRETE JOINTS.
4. PROVIDE BROOM FINISH.
5. D = 3.5" MINIMUM THICKNESS FOR ALL RESIDENTIAL WALKS & PATIOS (5" THICKNESS PREFERRED)
6. ALL SERVICE WALKS AND PATIOS SHALL BE BUILT PER THE VILLAGE OF BENSENVILLE CODE.
7. COMPACTED STONE BASE SHALL BE (CA-6, GRADE 8 OR GRADE 9) VIRGIN MATERIAL, CRUSHED LIMESTONE.



VILLAGE OF BENSENVILLE
 12 S. CENTER STREET
 BENSENVILLE, IL 60106
 WWW.BENSENVILLE.IL.US

**SERVICE WALK AND PATIO
 STANDARDS**

VILLAGE OF BENSENVILLE SPECIFICATIONS AND DETAILS		REVISIONS	
FILE LOCATION			
G:\ENGINEERING\STANDARDS\NEW STANDARDS\ROADWAY			