



12 South Center Street
Bensenville, IL 60106

Office: 630.350.3404
Fax: 630.350.3438
www.bensenville.il.us

VILLAGE BOARD

President
Frank DeSimone

Board of Trustees
Rosa Carmona
Ann Franz
Agnieszka "Annie" Jaworska
McLane Lomax
Nicholas Panicola Jr.
Armando Perez

Village Clerk
Nancy Quinn

Village Manager
Evan K. Summers

June 19, 2018

Mr. Tim Peifer
135 South LaSalle Street
Chicago, Illinois 60603

Re: June 19, 2018 FOIA Request

Dear Mr. Peifer:

I am pleased to help you with your June 19, 2018 Freedom of Information Act ("FOIA"). The Village of Bensenville received your request on June 19, 2018. You requested copies of the items indicated below:

"any open violations of building or zoning codes for 304 Meyer Road."

After a search of Village files, the following documents are enclosed to fulfill your request:

- 1) Village of Bensenville Certificate of Compliance for Inspection No. 35290. (1 pg.)

These are all of the documents that can be discovered responsive to your request.

Do not hesitate to contact me if you have any questions or concerns in connection with this response.

Very truly yours,

Corey Williamsen
Freedom of Information Officer
Village of Bensenville

Village of Bensenville
Department of Community and Economic Development
12 S. Center Street, Bensenville, IL 60106
Phone: 630.350.3413 Fax: 630.350.3449

CERTIFICATE OF COMPLIANCE

For: 2015 NON-RESIDENTIAL

ANNUAL INSPECTION

Inspection Number: 35290

DATE: May 6, 2015

This certifies that:

Mid State Cutting Tools Inc.

304 Meyer Road,

Bensenville, IL 60106

Has been inspected and satisfactorily passed inspection.

Business may continue on the current issued Village License.

Exit Lights to be lit at all times and Emergency Back-Up lights need to function as designed and illuminate upon testing. If either of these lights do not illuminate upon testing, the battery may need to be changed or the entire unit needs replacing

All fire extinguishers need to be a minimum of 10# ABC rated and tested every year with a correct corresponding tag showing test month and year. Fire extinguisher must be mounted no more than 48 inches from floor to top of extinguisher.

LINDSAY LAYCOAX

Village of Bensenville Inspector

Village of Bensenville Inspector's Signature

KEEP THIS CERTIFICATE WITH YOUR DEED AND OTHER VALUABLE DOCUMENTS